

SGWA
Swiss Gas and Water
Industry Association
Grütlistrasse 44
CH- 8027 Zürich

Certification body water



Certificate No.: 1308 - 6179

Applicant for Certification: I.V.A.R. S.p.A., Via IV Novembre, 181, IT- 25080 Prevalle (BS)

from: 23.07.2013

The Swiss Gas and Water Industry Association (SGWA) certified, based on the technical standards W/TPW 101, the following article:

Rubric: Pressure reduction valve
Denomination: PRV / PRV NB
Types: PRV DN 15, -20, -25, -32, -40
PRV NB DN 15, -20, -25, -32, -40

DN: 15...40 PN: 16 tmax= 70°C

Certification Standard: SGWA W/TPW 111 (11/08), EN 1567

Validity: 30.09.2019

Notes / Conditions:

Acoustic group: II (PRV and PRV NB DN 15, -20, -25, -32)

The customer is entitled to offer the above mentioned products as certificated by the SGWA and to use the SGWA-conformity mark (publication in the list of certificates water).



accredited
according SN
EN 45011

SCESp 028
Zurich, 01.12.2014

Swiss Gas and Water Industry Association
Certification body water

Philipp Aschwanden
Head

Rubric: Pressure reduction valve

Denomination: PRV / PRV NB

Types	DN	PN	C°	Acoustic group	Losses	Content Index	Metrological class
PRV Art. No. 509126	15	16	70	II		-	
PRV Art. No. 509127	20	16	70	II		-	
PRV Art. No. 509128	25	16	70	II		-	
PRV Art. No. 509129	32	16	70	II		-	
PRV Art. No. 509130	40	16	70			-	
PRV NB Art. No. 509151	15	16	70	II		-	
PRV NB Art. No. 509152	20	16	70	II		-	
PRV NB Art. No. 509153	25	16	70	II		-	
PRV NB Art. No. 509154	32	16	70	II		-	
PRV NB Art. No. 509155	40	16	70			-	



Zertifikat Nr.: 1308 - 6179

Antragsteller: I.V.A.R. S.p.A., Via IV Novembre, 181, IT- 25080 Prevalle (BS)

vom: 23.07.2013

Gestützt auf das Prüf- und Zertifizierungsreglement der Technischen Prüfstelle Wasser (W/TPW 101) zertifiziert der SVGW die folgenden Serienprodukte:

Rubrik: Druckreduzierventile / Regelventile

Bezeichnung: PRV / PRV NB

Typen: PRV DN 15, -20, -25, -32, -40
PRV NB DN 15, -20, -25, -32, -40

DN: 15...40 PN: 16 tmax= 70°C

Zertifizierungsgrundlage: SVGW W/TPW 111 (11/08), EN 1567

Gültigkeit: 30.09.2019

Bemerkungen / Auflagen:

Armaturengeräuschgruppe: II (PRV and PRV NB DN 15, -20, -25, -32)

Der Auftraggeber ist berechtigt, die oben erwähnten Produkte als SVGW zertifiziert anzubieten und das SVGW-Konformitätszeichen zu verwenden (Publikation im Zertifizierungsverzeichnis Wasser).



akkreditiert nach
SN EN 45011

SCESp 028
Zürich, 01.12.2014

Schweizerischer Verein des Gas- und Wasserfaches
Zertifizierungsstelle Wasser

Philipp Aschwanden
Leiter

Rubrik: Druckreduzierventile / Regelventile

Bezeichnung: PRV / PRV NB

Typen	DN	PN	C°	Geräusch- gruppe	Verluste kWh/24 h	Inhalt	Index	Metrologische Klasse
PRV Art. No. 509126	15	16	70	II		-		
PRV Art. No. 509127	20	16	70	II		-		
PRV Art. No. 509128	25	16	70	II		-		
PRV Art. No. 509129	32	16	70	II		-		
PRV Art. No. 509130	40	16	70			-		
PRV NB Art. No. 509151	15	16	70	II		-		
PRV NB Art. No. 509152	20	16	70	II		-		
PRV NB Art. No. 509153	25	16	70	II		-		
PRV NB Art. No. 509154	32	16	70	II		-		
PRV NB Art. No. 509155	40	16	70			-		